

# Device Summary

Powered by  
**SONICU.COM**  
(05/07/2021 - 05/13/2021)

Device Name	Minimum	Average	Maximum	# Alarms
<b>Main Pharmacy</b>				
ARC Humidity	34.5%RH	42.2%RH	45.4%RH	0
ARC Temperature	22.0°C	22.5°C	24.9°C	0
ARCPressure	0.0149inWC	0.0154inWC	0.0160inWC	0
<b>Training Area</b>				
6B40 Input 2 Humidity	27.9%RH	36.5%RH	38.1%RH	0
Office Glycol	71.6°F	72.2°F	73.2°F	1
Office J Pharmacy Temp	22.3°C	22.9°C	23.8°C	0
Office Solid Buffer	22.6°C	23.0°C	23.6°C	0
Office Solid Buffer 2	21.9°C	22.7°C	23.4°C	0
Office Temp (MVP410)	71.3°F	72.1°F	73.7°F	0
Room 1 Temp	71.9°F	72.8°F	80.0°F	2
Room 6 Humidity	30.7%RH	38.7%RH	42.5%RH	0
<b>_New Points</b>				